




TOP VIEW



END VIEW



FRONT VIEW

4	REVISE FOR IN-HOUSE FABRICATION	JB	3/14/13
3	REVISE STANDARDS	JB	8/23/07
2	REVISE CARBON FILL	JB	6/18/07
1	CHANGE PRESSURE RATING TO 1 PSI	JB	3/8/07
NO.	REVISION	BY	DATE

PROJECT

NB-8

PROJ. NO. SALES
P.O. NO.

THIS DRAWING AND DESIGN ARE THE PROPERTY OF TIGG CORP. AND SHALL NOT BE REPRODUCED IN WHOLE OR IN PART, NOR EMPLOYED FOR ANY PURPOSE OTHER THAN SPECIFICALLY PERMITTED IN WRITING BY TIGG CORP. THIS DRAWING LOANED SUBJECT TO RETURN ON DEMAND.

DRAWN BY JB
DESIGN BY JB
CHKD. BY BB
DATE 11/11/05
SCALE NTS



PLAN & ELEVATION

DWG. NO. NB-8-1001

REV. 4

VESSEL STANDARDS

VESSEL MATERIALS : SA-36	LIQUID DRAIN ASSEMBLY : 3/4" NPT
LINING : EPOXY	VOLUME OF MEDIA BED : 250 FT ³
EXTERIOR PAINT : EPOXY BASE W/ URETHANE TOP COAT	SHIP WT. EMPTY : 7,000 LBS
INTERNALS : 304 STAINLESS STEEL POR-O-SEPTA	MAX. OPERATING PRESSURE : 1 PSI
VESSEL ACCESS : 20" HINGED MANWAY. (2 PLCS.)	MAX. OPERATING TEMPERATURE. : 180°